

CONTRACTING AUTHORITY'S CLARIFICATIONS No. 1

Contract title: **Construction of 2 bicycle service points for the project Baja-Sombor Greenways**

Publication Ref: **HUSRB/1602/31/0227-8/bicycle service points 7.1.1**

No.	Question	Answer
1.	In VOLUME 4 "Bill of quantities" under c) "Electrical installations" is stated For position no. 1 "Supply and installation of bathroom heater. The calculation is done piece by piece". Please explain what strength should be the heater and does heater with 2000 W is acceptable.	Heater with strength 2000 W is acceptable.
2.	In VOLUME 4 "Bill of quantities" under c) "Electrical installations" is stated For position no. 5 "Metal switch cabinet with key". Please explain the purpose of metal cabinet with key. If it is electro cabinet, one-pole scheme should be available.	Metal switch cabinet must be with triangular key.
3.	In VOLUME 4 "Bill of quantities" under c) "Electrical installations" is stated For position no. 6 "Circuit breakers". Please explain what types of switches are requested (single-pole, alternating, serial). Please explain are they OG or wall-mounted.	Switches must be single-pole OG.
4.	In VOLUME 4 "Bill of quantities" under c) "Electrical installations" is stated For position no. 7 "Shuko OG connectors". Please explain are the connectors single-phase or three-phase connectors.	Connectors must be single-phase.